



Garden State Laboratories, Inc.

Report of Analysis

410 Hillside Ave.
Hillside, NJ 07205

Telephone: 800-273-8901
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
NJDEP Lab Cert. #20044

Jersey Shore Lab
NJDEP Lab Cert. #15037

Lakehurst Lab
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Manager Emerita

For: Lower Cape May Regional School District
687 US Rt. 9

Cape May, NJ 08204

Laboratory Director:

Attention: Mark Mallett

Client Number: LOW02

Report Date: 06/05/2025

Sample ID: Field Blank Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-01

Site: Collection Date/Time: 05/17/2025 07:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:02	

Sample ID: LCMRMT-POE-IFL-01 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-02

Site: Collection Date/Time: 05/17/2025 07:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00330 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:05	

Sample ID: LCMRMT-WC-IFL-02 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-03

Site: Collection Date/Time: 05/17/2025 07:52

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:16	

Sample ID: LCMRMT-WC-IFL-03 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-04

Site: Collection Date/Time: 05/17/2025 07:53

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:19	



Garden State Laboratories, Inc.

Sample ID: LCMRMT-KO-IFL-04 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-05

Site: Collection Date/Time: 05/17/2025 07:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00544 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:22	

Sample ID: LCMRMT-KO-IFL-05 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-06

Site: Collection Date/Time: 05/17/2025 07:56

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.0137 mg/l	0.015	0.00100	0.00055	20044	05/30/25 17:24	

Sample ID: LCMRMT-TL-IFL-06 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-07

Site: Collection Date/Time: 05/17/2025 07:57

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00874 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:32	

Sample ID: LCMRMT-WC-IFL-07 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-08

Site: Collection Date/Time: 05/17/2025 07:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:35	

Sample ID: LCMRMT-WC-IFL-09 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-09

Site: Collection Date/Time: 05/17/2025 07:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:44	



Garden State Laboratories, Inc.

Sample ID: LCMRMT-TL-1FL-10 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-10

Site: Collection Date/Time: 05/17/2025 08:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:47	

Sample ID: LCMRMT-NS-1FL-11 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-11

Site: Collection Date/Time: 05/17/2025 08:02

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8		1	0.00131 mg/l	0.015	0.00100	0.00032	20044	06/04/25 20:59	

Sample ID: LCMRMT-NS-1FL-12 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-12

Site: Collection Date/Time: 05/17/2025 08:04

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:49	

Sample ID: LCMRMT-IC-1FL-13 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-13

Site: Collection Date/Time: 05/17/2025 08:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:52	

Sample ID: LCMRMT-WC-1FL-14 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204 Lab Sample ID: 250521079-14

Site: Collection Date/Time: 05/17/2025 08:06

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 12:55	



Garden State Laboratories, Inc.

Sample ID: LCMRMT-DW-1FL-15 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-15

Site: Collection Date/Time: 05/17/2025 08:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:04	

Sample ID: LCMRMT-TL-1FL-17 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-16

Site: Collection Date/Time: 05/17/2025 08:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:06	

Sample ID: LCMRMT-WC-1FL-18 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-17

Site: Collection Date/Time: 05/17/2025 08:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:09	

Sample ID: LCMRMT-DW-1FL-19 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-18

Site: Collection Date/Time: 05/17/2025 08:13

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:12	

Sample ID: LCMRMT-TL-1FL-21 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204
Lab Sample ID: 250521079-19

Site: Collection Date/Time: 05/17/2025 08:14

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00298 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:15	



Garden State Laboratories, Inc.

Sample ID: LCMRMT-WC-2FL-23 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-20

Site: Collection Date/Time: 05/17/2025 08:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:17	

Sample ID: LCMRMT-TL-2FL-25 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-21

Site: Collection Date/Time: 05/17/2025 08:17

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:20	

Sample ID: LCMRMT-DW-2FL-26 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-22

Site: Collection Date/Time: 05/17/2025 08:18

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:23	

Sample ID: LCMRMT-WC-2FL-28 Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-23

Site: Collection Date/Time: 05/17/2025 08:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:26	

Sample ID: Field Blank Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-24

Site: Collection Date/Time: 05/17/2025 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:29	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-POE-01 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-25

Site: Collection Date/Time: 05/17/2025 06:32

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.0200 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:40	

Sample ID: LCMRHS-TL-03 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-26

Site: Collection Date/Time: 05/17/2025 06:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:43	

Sample ID: LCMRHS-IC-04 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-27

Site: Collection Date/Time: 05/17/2025 06:34

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:49	

Sample ID: LCMRHS-DW-05 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-28

Site: Collection Date/Time: 05/17/2025 06:35

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 13:57	

Sample ID: LCMRHS-KC-06 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-29

Site: Collection Date/Time: 05/17/2025 06:36

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00226 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:00	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-FP-08 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-30

Site: Collection Date/Time: 05/17/2025 06:37

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00687 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:03	

Sample ID: LCMRHS-KC-09 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-31

Site: Collection Date/Time: 05/17/2025 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00269 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:06	

Sample ID: LCMRHS-FP-10 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-32

Site: Collection Date/Time: 05/17/2025 06:38

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.0105 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:14	

Sample ID: LCMRHS-WC-11 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-33

Site: Collection Date/Time: 05/17/2025 06:40

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:17	

Sample ID: LCMRHS-NS-12 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-34

Site: Collection Date/Time: 05/17/2025 06:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00103 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:20	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-IC-13 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-35

Site: Collection Date/Time: 05/17/2025 06:42

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:23	

Sample ID: LCMRHS-WC-14 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-36

Site: Collection Date/Time: 05/17/2025 06:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:25	

Sample ID: LCMRHS-TL-16 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-37

Site: Collection Date/Time: 05/17/2025 06:46

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00771 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:28	

Sample ID: LCMRHS-TL-17 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-38

Site: Collection Date/Time: 05/17/2025 06:48

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00280 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:31	

Sample ID: LCMRHS-WC-18 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-39

Site: Collection Date/Time: 05/17/2025 06:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:34	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-TL-19 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-40

Site: Collection Date/Time: 05/17/2025 06:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00170 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:37	

Sample ID: LCMRHS-EC-20 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-41

Site: Collection Date/Time: 05/17/2025 06:52

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00341 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:40	

Sample ID: LCMRHS-EC-21 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-42

Site: Collection Date/Time: 05/17/2025 06:54

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:51	

Sample ID: LCMRHS-WC-23 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-43

Site: Collection Date/Time: 05/17/2025 06:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:54	

Sample ID: LCMRHS-WC-26 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-44

Site: Collection Date/Time: 05/17/2025 06:57

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00372 mg/l	0.015	0.00100	0.00055	20044	06/02/25 14:57	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-EC-27 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-45

Site: Collection Date/Time: 05/17/2025 06:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:02	

Sample ID: LCMRHS-EC-28 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-46

Site: Collection Date/Time: 05/17/2025 06:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:11	

Sample ID: LCMRHS-EC-29 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-47

Site: Collection Date/Time: 05/17/2025 06:59

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00105 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:14	

Sample ID: LCMRHS-EC-30 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-48

Site: Collection Date/Time: 05/17/2025 07:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00120 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:17	

Sample ID: LCMRHS-WC-32 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-49

Site: Collection Date/Time: 05/17/2025 07:03

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:25	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-TL-33 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-50

Site: Collection Date/Time: 05/17/2025 07:05

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:28	

Sample ID: LCMRHS-TL-35 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-51

Site: Collection Date/Time: 05/17/2025 07:06

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:31	

Sample ID: LCMRHS-TL-36 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-52

Site: Collection Date/Time: 05/17/2025 07:08

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00142 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:33	

Sample ID: LCMRHS-KC-37 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-53

Site: Collection Date/Time: 05/17/2025 07:10

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00136 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:36	

Sample ID: LCMRHS-FP-38 Lower Cape
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Lab Sample ID: 250521079-54

Site: Collection Date/Time: 05/17/2025 07:11

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00268 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:39	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-IC-39 Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-55

Site: Collection Date/Time: 05/17/2025 07:13

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00276 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:42	

Sample ID: LCMRHS-FP-40 Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-56

Site: Collection Date/Time: 05/17/2025 07:14

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:45	

Sample ID: LCMRHS-FP-41 Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-57

Site: Collection Date/Time: 05/17/2025 07:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:47	

Sample ID: Field Blank Lower Cape May Regional School (CONCESSION) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-58

Site: Collection Date/Time: 05/17/2025 07:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 15:50	

Sample ID: LCMRHS-DW-43 Lower Cape May Regional School (CONCESSION) - 687 US Rt. 9 Cape May, NJ. 08204

Lab Sample ID: 250521079-59

Site: Collection Date/Time: 05/17/2025 07:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:02	



Garden State Laboratories, Inc.

Sample ID: LCMRHS-DW-44 Lower Cape Lab Sample ID: 250521079-60
May Regional School
(CONCESSION) - 687 US Rt. 9
Cape May, NJ. 08204

Site: Collection Date/Time: 05/17/2025 07:23

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:04	

Sample ID: LCMRHS-DW-45 Lower Cape Lab Sample ID: 250521079-61
May Regional School
(CONCESSION) - 687 US Rt. 9
Cape May, NJ. 08204

Site: Collection Date/Time: 05/17/2025 07:24

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00251 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:07	

Sample ID: LCMRHS-EC-31 Lower Cape Lab Sample ID: 250521079-62
May Regional School (MAIN
BUILDING) - 687 US Rt. 9
Cape May, NJ. 08204

Site: Collection Date/Time: 05/17/2025 07:02

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:10	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ 08204

GrabComp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	☐ List attached	Total Pages _____	No.	Type*	Size	Pres *	
X	LCMRMT-KO-1FL-05	5/17/25	0756	X				1	P	250ml	A	
X	LCMRMT-TL-1FL-06	5/17/25	0757	X				1	P	250ml	A	
X	LCMRMT-WC-1FL-07	5/17/25	0758	X				1	P	250ml	A	
X	LCMRMT-WC-1FL-09	5/17/25	0758	X				1	P	250ml	A	
X	LCMRMT-TL-1FL-10	5/17/25	0800	X				1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tiro V = Vial U = Ureter/Specimen
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
L = Hydrochloric Acid R = Zinc Acetate G = Sodium Ionsuarate H = Ascorbic Acid I = Cooled Ureter/Specimen

TURNAROUND TIME: Standard Report

Standard Report ☐ Rush (if Rush requested) Rush Due by:

REPORT FORM: Standard Report

Standard Report + E2 ☐ Other/Specify:

PWSID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$

Credit Card Type: ☐ Composite Fee: \$

☐ Check # ☐ Rush Fee: \$

Amount Due: \$

Payment Method: ☐ Credit Card Type:

☐ Check # ☐ Other:

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY. USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

Client/Client's Representative (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swenson*

Signature: *Shelby Swenson*

Date/Time: 5-17-25 0900

2. Received/Relinquished by (PRINT): *KANIEL EVANS*

Signature: *KANIEL EVANS*

Date/Time: 5/31/25 14:31

The liability of Garden State Laboratories, Inc. for services rendered shall in no event be more than the amount of the invoice.
Main Lab certified by NJ Dept. of Health, NJDEP-TN, NY Dept. of Health #11557 and PADEP #06-05680

FOR SAMPLE RECEIVING USE ONLY
DATE/TIME/TEMP. RECD AT LAB:
5/21/25 14:31 0.8°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 35051079-06-10

SAMPLE RECD BY:

☐ FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco

Mailing Address: 687 US Rt. 9 Phone: 609-780-5113

City/State/Zip: Cape May, N.J. 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Richard M Teitleman School - 687 US Rt. 9 Cape May, N.J. 08204

SAMPLE ID

GrabComp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)			CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	☐ List attached	Total Pages	No.	Type	Size	Pres.	Extension
X	LCMRMT-NS-1FL-11	5/17/25	0802	X		Lead (First Draw)		1	P	250ml	A	
X	LCMRMT-NS-1FL-12	5/17/25	0804	X		Lead (First Draw)		1	P	250ml	A	
X	LCMRMT-IC-1FL-13	5/17/25	0805	X		Lead (First Draw)		1	P	250ml	A	
X	LCMRMT-WC-1FL-14	5/17/25	0806	X		Lead (First Draw)		1	P	250ml	A	
X	LCMRMT-DW-1FL-15	5/17/25	0808	X		Lead (First Draw)		1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile (Info) V = Vial Other/Specify: _____
 Preservation Code: A = Not Preserved B = Sodium Hydroxide D = Nitric Acid
 L = Hydrochloric Acid P = Zinc Acetate S = Sodium Iodide H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☐ Standard ☐ Rush (if rush requested) Rush Due by: _____

REPORT FORM: ☐ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWSID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ Amount Due: \$

Payment Method: ☐ Credit Card Type: ☐ Check # ☐ Other: _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swanson* 5/22/25 Signature: *Shelby Swanson* 5/22/25

Date/Time: 5-17-25 0900

2. Received/Relinquished by (PRINT): *Kouira Evans* Signature: *Kouira Evans*

Date/Time: 5/21/25 1123

The liability of Garden State Laboratories, Inc. for services rendered shall in no way exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TTL, NY Dept. of Health and PADOEP #88-03880

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. RECD AT LAB: 5/21/25 14:31 25°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 250531079-11-15

SAMPLE RECD BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

5/22/25

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside, NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown, NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-337-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATI Richard M Teitleman School - 687 US Rt. 9 Cape May, NJ. 08204

SAMPLE ID

GrabComp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)			CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	List attached	Total Pages	No	Type*	Size	Pres.*	Extension
X	LCMRMT-TL-1FL-17	5/17/25	0810	X				1	P	250ml	A	
X	LCMRMT-WC-1FL-18	5/17/25	0811	X				1	P	250ml	A	
X	LCMRMT-DW-1FL-19	5/17/25	0813	X				1	P	250ml	A	
X	LCMRMT-TL-1FL-21	5/17/25	0814	X				1	P	250ml	A	
X	LCMRMT-WC-2FL-23	5/17/25	0815	X				1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tiro V = Vial Urine/Spec: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodate H = Ascorbic Acid I = Cooled Urine/Spec: _____

TURNAROUND TIME: Standard Report Rush (if rush requested) Rush Due by:

REPORT FORM: Standard Report PWSID#: Other/Specify:

PAYMENT INFORMATION: Standard Report + E2 PWSID#: Other/Specify: SUBCONTRACTED WORK

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Other: Amount Due: \$

Payment Method: Credit Card Type: Check # Other:

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco Signature: *Matthew V. Franco*

Client/Clients Representative (PRINT): Matthew V. Franco Signature: *Matthew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swenson* Signature: *Shelby Swenson*

2. Received/Relinquished by (PRINT): *Karen Evans* Signature: *Karen Evans*

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJ Dept. of Health, NJDEP-TNL, NY Dept. of Health and PADER 4628-0280

FOR SAMPLE RECEIVING USE ONLY
DATE/TIME/TEMP. RECD AT LAB: 5/21/25 14:31 C. 8°C

Page of

GSL CLIENT # LOW02

MICRO #

CHEM. # 250521079-16-30

SAMPLE RECD BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco

Mailing Address: 687 US Rt. 9 Phone: 609-780-5113

City/State/Zip: Cape May, NJ, 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Richard M Teilleman School - 687 US Rt. 9 Cape May, NJ, 08204

SAMPLE ID

Grab Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	List attached	Total Pages	No.	Type*	Size	Pres.*
X	LCMRMT-TL-2FL-25	5/17/25	0817	X				1	P	250ml	A
X	LCMRMT-DW-2FL-26	5/17/25	0818	X				1	P	250ml	A
X	LCMRMT-WC-2FL-28	5/17/25	0819	X				1	P	250ml	A

Container type: P = Plastic G = Glass A = Amber Glass T = Sterile Tins V = Vial Others Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
L = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Others Specify: _____

TURNAROUND TIME: Standard ☐ Rush (if Rush requested) Rush Due by: _____

REPORT FORM: Standard Report ☐ Other/Specify: _____

Standard Report + E2 PWSID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Check # ☐ Rush Fee: \$ ☐ Other: _____

Payment Method: ☐ Credit Card Type: _____ Amount Due: \$ _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

Client/Client's Representative (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Simpson*

Signature: *Shelby Simpson*

Date/Time: 5-17-25 0900

2. Received/Relinquished by (PRINT): *Kamie Evans*

Signature: *Kamie Evans*

Date/Time: 5/21/25 1123

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/24/25 14:31 C.3°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 250521079 - 21-2.3

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

Lab #

Extension

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08836 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco

Mailing Address: 687 US Rt. 9 Phone: 609-780-5113

City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ 08204

SAMPLE ID

Grab Comp	SAMPLE ID	Date	Time	AM	PM	ANALYSIS REQUIRED (Print Legibly)	No.	Type*	Size	Pres.*	Lab #
X	Field Blank	5/17/25	0632	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-POE-01	5/17/25	0632	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-03	5/17/25	0633	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-IC-04	5/17/25	0634	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-DW-05	5/17/25	0635	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tint V = Vial Other/Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodate H = Ascorbic Acid I = Coolies Other/Specify: _____

TURNAROUND TIME: ☐ Standard ☐ Rush (if Rush requested) Rush Due by: _____

REPORT FORM: ☐ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWSID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: _____

Payment Method: ☐ Credit Card Type: ☐ Check # _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

Client/Client's Representative (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swanson*

Signature: *Shelby Swanson*

Date/Time: 5-17-25 0700

2. Received/Relinquished by (PRINT): *Megan Horanich*

Signature: *Megan Horanich*

Date/Time: 5/21/25 14:31

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB: _____

5/21/25 14:31 0.6°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO # _____

CHEM. # 152521079-24-28

SAMPLE REC'D BY: _____

☐ GSL FIELD SAMPLE PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CONTAINER INFORMATION

☐ SUBCONTRACTED WORK

SEND TO: _____

DATE/TIME: _____

METHOD OF SHIPMENT: _____

Amount Due: \$ _____

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1837
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District **Contact/Authorized by:** Matt Franco
Mailing Address: 687 US Rt. 9 **Phone:** 609-780-5113
City/State/Zip: Cape May, NJ 08204 **Fax:** mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ 08204

GrabComp		SAMPLE ID				SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			Lab #
			Date	Time	AM	PM	☐ List attached	Total Pages		No.	Type*	Size	Pres.	Extension	
X		LCMRHS-KC-06	5/17/25	0636	X		Lead (First Draw)			1	P	250ml	A		
X		LCMRHS-FP-08	5/17/25	0637	X		Lead (First Draw)			1	P	250ml	A		
X		LCMRHS-KC-09	5/17/25	0638	X		Lead (First Draw)			1	P	250ml	A		
X		LCMRHS-FP-10	5/17/25	0638	X		Lead (First Draw)			1	P	250ml	A		
X		LCMRHS-WC-11	5/17/25	0640	X		Lead (First Draw)			1	P	250ml	A		

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tinfo V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodide H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if rush requested) Rush Due by: _____

REPORT FORM: ☒ Standard Report ☐ Other/Specify: _____
☐ Standard Report + E2 PWSID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: _____
 Amount Due: \$ _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee
SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

1. Received/Relinquished by (PRINT): *Shelly S. Sussman*

Signature: *Shelly S. Sussman*

Date/Time: 5-17-25 0900

2. Received/Relinquished by (PRINT): *Megan H. Hannon*

Signature: *Megan H. Hannon*

Date/Time: 5/21/25 11:23

5/21/25

5/21/25

FOR SAMPLE RECEIVING USE ONLY
DATE/TIME/TEMP. REC'D AT LAB: 5/21/25 14:31 C.C.C.

Page _____ **of** _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 25051079-29-33

SAMPLE REC'D BY:

☐ **GSL FIELD SAMPLER/PICK-UP**

☐ **PICK-UP AT DROP OFF LOCATION**

☐ **DELIVERED BY CLIENT**

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TN, NY Dept. of Health #11560 and PADEP #08-03660

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside, NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown, NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco

Mailing Address: 687 US Rt. 9 Phone: 609-780-5113

City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ. 08204

SAMPLE ID

Grab Comp	SAMPLE ID	Date	Time	AM	PM	ANALYSIS REQUIRED (Print Legibly)	No.	Type*	Size	Pres.*	Lab #
X	LCMRHS-NS-12	5/17/25	0642	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-IC-13	5/17/25	0642	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-WC-14	5/17/25	0645	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-16	5/17/25	0646	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-17	5/17/25	0648	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Time V = Vial Other Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodide H = Ascorbic Acid I = Cooled Ultrasonic

TURNAROUND TIME: Standard ☐ Rush (if Rush requested) Rush Due by: _____

REPORT FORM: Standard Report ☐ PWSID# _____ Other/Specify: _____

Standard Report + E2 ☐

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: _____

Payment Method: ☐ Credit Card Type: ☐ Check # _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

1. Received/Reinquished by (PRINT): *Shelby Swensen*

Signature: *Shelby Swensen*

Date/Time: 5-17-25 0900

2. Received/Reinquished by (PRINT): *Megan Horanich*

Signature: *Megan Horanich*

Date/Time: 5/21/25 1123

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.

Main Lab certified by NJ Dept. of Health, NJDEP-TN1, NY Dept. of Health #1550 and PADEP #69-03060

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. RECD AT LAB:

5/21/25 14:31 06°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 250521079-34-32

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CONTAINER INFORMATION

No.	Type*	Size	Pres.*	Lab #
1	P	250ml	A	
1	P	250ml	A	
1	P	250ml	A	
1	P	250ml	A	
1	P	250ml	A	

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

Amount Due: \$

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-337-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DWI

SAMPLE LOCATI Lower Cape May Regional School(MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ 08204

SAMPLE ID

GrabCont	SAMPLE ID	DATE	TIME	AM	PM	ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION	Lab #
X	LCMRHS-WC-18	5/17/25	0650	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-TL-19	5/17/25	0651	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-EC-20	5/17/25	0652	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-EC-21	5/17/25	0654	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-WC-23	5/17/25	0655	X		Lead (First Draw)	1 P 250ml A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ino V = Vial C = Cuvette
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodate H = Ascorbic Acid I = Copper Uter/Specy

TURNAROUND TIME: ☐ Standard ☐ Rush (if RUSH requested) Rush Due by:

REPORT FORM: ☐ Standard Report ☐ Other/Specify: PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Credit Card Type: ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: Amount Due: \$

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee
SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

Client/Client's Representative (PRINT): Matthew V. Franco

Signature: *Matthew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swanson*

Signature: *Shelby Swanson*

Date/Time: 5/17-25 0900

Date/Time: 5/17/25 1123

2. Received/Relinquished by (PRINT): *Morgan Harrison*

Signature: *Morgan Harrison*

Date/Time: 5/21/25 14:31

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. RECD AT LAB:

5/21/25 14:31 0-6°C

Page of

GSL CLIENT # LOW02

MICRO #

CHEM. # 250521079-39-43

SAMPLE RECD BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DWI

SAMPLE LOCATI Lower Cape May Regional School(MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ 08204

SAMPLE ID

GratComp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)			CONTAINER INFORMATION				Lab #
		Date	Time	AM	PM	List Attached	Total Pages		No.	Type*	Size	Pres.*	
X	LCMRHS-WC-26	5/17/25	0657	X				Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-EC-27	5/17/25	0658	X				Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-EC-28	5/17/25	0658	X				Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-EC-29	5/17/25	0659	X				Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-EC-30	5/17/25	0700	X				Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass J = Sterile Tins V = Vial Urine/Specimen
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Fluoride H = Ascorbic Acid I = Copper Urine/Specimen

TURNAROUND TIME: ☐ Standard Report ☐ Rush (If Rush Requested) Rush Due by:

REPORT FORM: ☐ Standard Report ☐ Other/Specify: PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Credit Card Type: ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: Amount Due: \$

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Matthew V. Franco

Client/Clients Representative (PRINT): Matthew V. Franco

1. Received/Relinquished by (PRINT): Shelby Swanson

2. Received/Relinquished by (PRINT): Meghan Edwards

Signature: *Matthew V. Franco* Date/Time: 5-17-25 0900

Signature: *Shelby Swanson* Date/Time: 5/21/25 1123

Signature: *Meghan Edwards* Date/Time: 5/21/25 14:23

FOR SAMPLE RECEIVING USE ONLY
DATE/TIME/TEMP. REC'D AT LAB: 5/21/25 14:31 C. 6°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 250521079-44-48

SAMPLE REC'D BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

☐ SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ 08204

SAMPLE ID

Grab Cont	SAMPLE ID	Date	Time	AM	PM	ANALYSIS REQUIRED (Print Legibly)	No.	Type*	Size	Pres.*	Lab #
X	LCMRHS-EC-31	5/17/25	0702	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-WC-32	5/17/25	0703	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-33	5/17/25	0705	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-35	5/17/25	0706	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-TL-36	5/17/25	0708	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tinted V = Vial Others Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodate H = Ascorbic Acid I = Cooled Others Specify: _____

TURNAROUND TIME: ☒ Standard ☐ Rush (if rush requested) Rush Due by: _____

REPORT FORM: ☒ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2 PWSID#: _____

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: _____

Payment Method: ☐ Credit Card Type: ☐ Check # _____ Amount Due: \$ _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

1. Received/Relinquished by (PRINT): *Shelby Swanson*

Signature: *Shelby Swanson*

2. Received/Relinquished by (PRINT): *Mathew V. Franco*

Signature: *Mathew V. Franco*

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. RECD AT LAB: *5/21/25 14:31 26°C*

Page _____ of _____

GSL CLIENT # LOW02

MICRO # *49-53162*

CHEM. # *250521079-48-58*

SAMPLE RECD BY: _____

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

CONTAINER INFORMATION

Lab # _____

Extension _____

SEND TO: _____

DATE/TIME: _____

METHOD OF SHIPMENT: _____

☐ SUBCONTRACTED WORK

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside, NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown, NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08836 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco
Mailing Address: 687 US Rt. 9 Phone: 609-780-5113
City/State/Zip: Cape May, NJ, 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (MAIN BUILDING) - 687 US Rt. 9 Cape May, NJ, 08204

SAMPLE ID

Grab Cont	SAMPLE ID	DATE	TIME	AM	PM	ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION	Lab #
X	LCMRHS-KC-37	5/17/25	0710	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-FP-38	5/17/25	0711	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-IC-39	5/17/25	0713	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-FP-40	5/17/25	0714	X		Lead (First Draw)	1 P 250ml A	
X	LCMRHS-FP-41	5/17/25	0715	X		Lead (First Draw)	1 P 250ml A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tint V = Vial Other Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodide H = Ascorbic Acid I = Cooled Other Specify: _____

TURNAROUND TIME: ☐ Standard ☐ Rush (if Rush requested) Rush Due by: _____

REPORT FORM: ☐ Standard Report ☐ Other/Specify: _____

☐ Standard Report + E2

PWSID#:

PAYMENT INFORMATION

☐ Sampling/Pick-up Fee: \$ ☐ Composite Fee: \$ ☐ Rush Fee: \$ ☐ Other: _____

Payment Method: ☐ Credit Card Type: _____

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY

WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: *Mathew V. Franco*

1. Received/Relinquished by (PRINT): *Shirley S. ...*

Signature: *Shirley S. ...*

Date/Time: 5-17-25 0700

2. Received/Relinquished by (PRINT): *KLIM ...*

Signature: *KLIM ...*

Date/Time: 5/21/25 1123

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
Main Lab certified by NJ Dept. of Health, NJDEP-TWL, NY Dept. of Health #11550 and PADEP #68-03860

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. RECD AT LAB:

5/21/25 14:31 06°C

Page _____ of _____

GSL CLIENT # LOW02

MICRO #

CHEM. # 356521079-53-57

SAMPLE RECD BY:

☐ GSL FIELD SAMPLER/PICK-UP

☐ PICK-UP AT DROP OFF LOCATION

☐ DELIVERED BY CLIENT

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside, NJ 07205 - NJDEP Lab Cert. #20044
Jersey Shore Lab - 54 Main Street, Waretown, NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08836 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Lower Cape May Regional School District Contact/Authorized by: Matt Franco

Mailing Address: 687 US Rt. 9 Phone: 609-780-5113

City/State/Zip: Cape May, NJ 08204 Fax: mfranco6133@yahoo.com

SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION: Lower Cape May Regional School (CONCESSION) - 687 US Rt. 9 Cape May, NJ 08204

SAMPLE ID

Grab Comp	SAMPLE ID	Date	Time	AM	PM	ANALYSIS REQUIRED (Print Legibly)	No.	Type*	Size	Pres*	Lab #
X	FIELD BLANK	5/17/25	0721	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-DW-43	5/17/25	0721	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-DW-44	5/17/25	0723	X		Lead (First Draw)	1	P	250ml	A	
X	LCMRHS-DW-45	5/17/25	0724	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tint V = Vial Other/Specify: _____
Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodide H = Ascorbic Acid I = Labeled Other/Specify: _____

TURNAROUND TIME: Standard Report Rush (if RUSH REQUESTED) Rush Due by: _____

REPORT FORM: Standard Report Other/Specify: _____

Standard Report + E2 PWSID#:

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Other: \$

Payment Method: Credit Card Type: Check # Amount Due: \$

Note: LEAD SAMPLING FOR BOE REGULATIONS *IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED* ADD Pick up Fee

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Mathew V. Franco

Signature: Mathew V. Franco

Client/Client's Representative (PRINT): Mathew V. Franco

Signature: Mathew V. Franco

1. Received/Reinquished by (PRINT): *Shelby S. Franco*

Signature: *Shelby S. Franco*

Date/Time: 5-17-25 0900

2. Received/Reinquished by (PRINT): *Mathew V. Franco*

Signature: *Mathew V. Franco*

Date/Time: 5/17/25 14:31

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB: 5/21/25 14:31 0.6°C

Page of

GSL CLIENT # LOW02

MICRO #

CHEM. # *250591079-58-623*

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CONTAINER INFORMATION

No.	Type*	Size	Pres*	Lab #
1	P	250ml	A	
1	P	250ml	A	
1	P	250ml	A	
1	P	250ml	A	

SUBCONTRACTED WORK

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

5/21/25