



Environment Testing
America

ANALYTICAL REPORT

Eurofins Environment Testing Philadelphia, LLC
213 Witmer Road
Horsham, PA 19044-0962
Tel: (215)355-3900

Laboratory Job ID: 630-34804-1
Client Project/Site: Richard M. Teitelman - Lead

For:
Lower Cape May Regional School District
687 Route 9
Cape May, New Jersey 08204

Attn: R Olsen

Nicki Smith

Authorized for release by:
6/10/2022 12:38:03 PM

Nicki Smith, Environmental Administration Manager
(215)355-3900
Nicolette.Smith@et.eurofinsus.com

LINKS

Review your project
results through



Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If your report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015

VL = field staff performs tests under NJ State certification #06005

WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).

Nicki Smith

Nicki Smith
Environmental Administration Manager
6/10/2022 12:38:03 PM

Case Narrative

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

2

Job ID: 630-34804-1

Laboratory: Eurofins Environment Testing Philadelphia, LLC

Narrative

Job Narrative
630-34804-1

Receipt

The samples were received on 5/31/2022 4:56 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-34804-1	LCMRMT-WC-1FL-02	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-2	LCMRMT-WC-1FL-03	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-3	LCMRMT-KO-1FL-04	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-4	LCMRMT-KO-1FL-05	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-5	LCMRMT-TL-1FL-06	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-6	LCMRMT-WC-1FL-07	Drinking Water	05/28/22 09:00	05/31/22 16:56
630-34804-7	LCMRMT-WC-1FL-08	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-8	LCMRMT-WC-1FL-09	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-9	LCMRMT-TL-1FL-10	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-10	LCMRMT-NS-1FL-11	Drinking Water	05/28/22 09:15	05/31/22 16:56
630-34804-11	LCMRMT-NS-1FL-12	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-12	LCMRMT-IC-1FL-13	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-13	LCMRMT-WC-1FL-14	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-14	LCMRMT-DW-1FL-15	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-15	LCMRMT-DW-1FL-16	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-16	LCMRMT-TL-1FL-17	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-17	LCMRMT-WC-1FL-18	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-18	LCMRMT-DW-1FL-19	Drinking Water	05/28/22 09:00	05/31/22 16:56
630-34804-19	LCMRMT-DW-1FL-20	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-20	LCMRMT-TL-1FL-21	Drinking Water	05/28/22 09:20	05/31/22 16:56
630-34804-21	LCMRMT-WC-2FL-23	Drinking Water	05/28/22 09:35	05/31/22 16:56
630-34804-22	LCMRMT-WC-2FL-24	Drinking Water	05/28/22 09:35	05/31/22 16:56
630-34804-23	LCMRMT-TL-2FL-25	Drinking Water	05/28/22 09:35	05/31/22 16:56
630-34804-24	LCMRMT-DW-2FL-26	Drinking Water	05/28/22 09:35	05/31/22 16:56

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-1FL-02

Lab Sample ID: 630-34804-1

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:59	1	UCIG

Client Sample ID: LCMRMT-WC-1FL-03

Lab Sample ID: 630-34804-2

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:48	1	UCIG

Client Sample ID: LCMRMT-KO-1FL-04

Lab Sample ID: 630-34804-3

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		06/10/22 01:50	1	UCIG

Client Sample ID: LCMRMT-KO-1FL-05

Lab Sample ID: 630-34804-4

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.0		1.0	0.69	ug/L		06/09/22 23:54	1	UCIG

Client Sample ID: LCMRMT-TL-1FL-06

Lab Sample ID: 630-34804-5

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.80	J	1.0	0.69	ug/L		06/10/22 01:20	1	UCIG

Client Sample ID: LCMRMT-WC-1FL-07

Lab Sample ID: 630-34804-6

Date Collected: 05/28/22 09:00

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 02:07	1	UCIG

Client Sample ID: LCMRMT-WC-1FL-08

Lab Sample ID: 630-34804-7

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 02:31	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-1FL-09

Lab Sample ID: 630-34804-8

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:46	1	UCIG

Client Sample ID: LCMRMT-TL-1FL-10

Lab Sample ID: 630-34804-9

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.7		1.0	0.69	ug/L		06/09/22 19:07	1	UCIG

Client Sample ID: LCMRMT-NS-1FL-11

Lab Sample ID: 630-34804-10

Date Collected: 05/28/22 09:15

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:12	1	UCIG

Client Sample ID: LCMRMT-NS-1FL-12

Lab Sample ID: 630-34804-11

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.7		1.0	0.69	ug/L		06/10/22 00:34	1	UCIG

Client Sample ID: LCMRMT-IC-1FL-13

Lab Sample ID: 630-34804-12

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:17	1	UCIG

Client Sample ID: LCMRMT-WC-1FL-14

Lab Sample ID: 630-34804-13

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:42	1	UCIG

Client Sample ID: LCMRMT-DW-1FL-15

Lab Sample ID: 630-34804-14

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:57	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-DW-1FL-16

Lab Sample ID: 630-34804-15

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:37	1	UCIG

Client Sample ID: LCMRMT-TL-1FL-17

Lab Sample ID: 630-34804-16

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	15		1.0	0.69	ug/L		06/09/22 21:35	1	UCIG

Client Sample ID: LCMRMT-WC-1FL-18

Lab Sample ID: 630-34804-17

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:10	1	UCIG

Client Sample ID: LCMRMT-DW-1FL-19

Lab Sample ID: 630-34804-18

Date Collected: 05/28/22 09:00

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:48	1	UCIG

Client Sample ID: LCMRMT-DW-1FL-20

Lab Sample ID: 630-34804-19

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:59	1	UCIG

Client Sample ID: LCMRMT-TL-1FL-21

Lab Sample ID: 630-34804-20

Date Collected: 05/28/22 09:20

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	5.1		1.0	0.69	ug/L		06/09/22 23:18	1	UCIG

Client Sample ID: LCMRMT-WC-2FL-23

Lab Sample ID: 630-34804-21

Date Collected: 05/28/22 09:35

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 02:24	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-2FL-24

Lab Sample ID: 630-34804-22

Date Collected: 05/28/22 09:35

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:26	1	UCIG

Client Sample ID: LCMRMT-TL-2FL-25

Lab Sample ID: 630-34804-23

Date Collected: 05/28/22 09:35

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.69	J	1.0	0.69	ug/L		06/09/22 23:40	1	UCIG

Client Sample ID: LCMRMT-DW-2FL-26

Lab Sample ID: 630-34804-24

Date Collected: 05/28/22 09:35

Matrix: Drinking Water

Date Received: 05/31/22 16:56

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:10	1	UCIG

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-1FL-02

Lab Sample ID: 630-34804-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-1FL-03

Lab Sample ID: 630-34804-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-KO-1FL-04

Lab Sample ID: 630-34804-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.3		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-KO-1FL-05

Lab Sample ID: 630-34804-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	3.0		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-TL-1FL-06

Lab Sample ID: 630-34804-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.80	J	ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-1FL-07

Lab Sample ID: 630-34804-6

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-1FL-08

Lab Sample ID: 630-34804-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-1FL-09

Lab Sample ID: 630-34804-8

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-TL-1FL-10

Lab Sample ID: 630-34804-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	3.7		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-NS-1FL-11

Lab Sample ID: 630-34804-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-NS-1FL-12

Lab Sample ID: 630-34804-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	3.7		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-IC-1FL-13

Lab Sample ID: 630-34804-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-WC-1FL-14

Lab Sample ID: 630-34804-13

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-DW-1FL-15

Lab Sample ID: 630-34804-14

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-DW-1FL-16

Lab Sample ID: 630-34804-15

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-TL-1FL-17

Lab Sample ID: 630-34804-16

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	15		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-1FL-18

Lab Sample ID: 630-34804-17

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-DW-1FL-19

Lab Sample ID: 630-34804-18

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Client Sample ID: LCMRMT-DW-1FL-20

Lab Sample ID: 630-34804-19

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-TL-1FL-21

Lab Sample ID: 630-34804-20

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	5.1		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-2FL-23

Lab Sample ID: 630-34804-21

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-WC-2FL-24

Lab Sample ID: 630-34804-22

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-TL-2FL-25

Lab Sample ID: 630-34804-23

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	0.69	J	ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRMT-DW-2FL-26

Lab Sample ID: 630-34804-24

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Accreditation/Certification and Definitions Summary

Client: Lower Cape May Regional School District
 Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-22

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count



Method Summary

Client: Lower Cape May Regional School District
Project/Site: Richard M. Teitelman - Lead

Job ID: 630-34804-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)856-2300

7

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

School Project Manager & Contact Information

NAME: Roy Olsen
 PHONE: (609)-884-3475 Ext:220

NAME: Eurofin
 ADDRESS & PH: _____
 LAB MGR: _____
 LAB QA DIRECT: _____



School Facility Information

SCHOOL FACILITY NAME: Lower Cape May Regional School District
 BLDG ID: Richard M. Teitleman
 BLDG ADDRESS: 687 Route 9 Cape May, NJ 08204
 CONTACT NAME & PHONE: Mathew Franco (609)-780-5113

MATRIX: DRINKING WATER Y/N _____
 SAMPLE TYPE: GRAB Y/N _____

DATE OF SAMPLING: 05/28/2022

AFFILIATION: Licensed Operator In Charge

SAMPLER NAME: Mathew V. Franco

SAMPLE DATA FOR LEAD ANALYSIS

Field Sample ID #	Sample Location ID (if different)	Check if Filter Present	Check if Flush	Time of Collection (military time)	# of Sample Bottles	pH<2	Observations
2	LCMRMT-WC-1FL-02			0915	1		
3	LCMRMT-WC-1FL-03			0915	1		
4	LCMRMT-WC-1FL-04			0915	1		
5	LCMRMT-WC-1FL-05			0915	1		
6	LCMRMT-TL-1FL-06	YES		0915	1		
7	LCMRMT-WC-1FL-07			0900	1		
8	LCMRMT-WC-1FL-08			0915	1		
9	LCMRMT-WC-1FL-09			0915	1		
10	LCMRMT-TL-1FL-10			0915	1		
11	LCMRMT-NS-1FL-11	YES		0915	1		
12	LCMRMT-NS-1FL-12	YES		0920	1		
13	LCMRMT-IC-1FL-13	YES		0920	1		
14	LCMRMT-WC-1FL-14			0920	1		
15	LCMRMT-DW-1FL-15			0920	1		
16	LCMRMT-DW-1FL-16			0920	1		

X All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃): _____

Relinquished:	Print Name	Sign Name	Affiliation	Date and Time
Received By: <i>Mathew V. Franco</i>	Mathew V. Franco	<i>Mathew V. Franco</i>	Licensed Operator in Charge	05/28/2022 1200
Relinquished:				
Received By:				
Relinquished:				
Received By:				

Method of shipment/delivery: _____ Fed-Ex _____ Hand Delivery _____ US Mail _____ UPS _____ Courier _____ Other _____
 To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY

Follow signed OAPP
 If initial first draw and follow up flush samples were collected on the same day:
 Analyze initial first draw and follow up flush samples together: Y/N _____
 Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N _____
 Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N _____
 Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

School Project Manager & Contact Information

NAME: Roy Olsen
 PHONE: (609)-884-3475 Ext:220

Laboratory Information

NAME: Eurofins QC, Inc.
 ADDRESS & PHONE:
 LAB MGR:
 LAB QA DIRECTOR:

School Facility Information

SCHOOL FACILITY NAME: Lower Cape May Regional School District
 BLDG ID: Richard M. Teirleman
 BLDG ADDRESS: 687 Route 9 Cape May, NJ 08204
 CONTACT NAME & PHONE: Mathew Franco (609)-780-5113

MATRIX: DRINKING WATER Y/N _____
 SAMPLE TYPE: GRAB Y/N _____

DATE OF SAMPLING: 05/28/2022

AFFILIATION: Licensed Operator in Charge

SAMPLER NAME: Mathew V. Franco

SAMPLE DATA FOR LEAD ANALYSIS

Field Sample ID #	Sample Location ID (if different)	Check if Filter Present	Check if Flush	Time of Collection (military time)	# of Sample Bottles	pH<2	Observations
17	LCMRMT-TL-1FL-17			0920	1		
18	LCMRMT-WC-1FL-18			0920	1		
19	LCMRMT-DW-1FL-19			0900	1		
20	LCMRMT-DW-1FL-20			0920	1		
21	LCMRMT-TL-1FL-21			0920	1		
23	LCMRMT-WC-2FL-23			0935	1		
24	LCMRMT-WC-2FL-24			0935	1		
25	LCMRMT-TL-2FL-25			0935	1		
26	LCMRMT-DW-2FL-26			0935	1		

All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃): _____

Relinquished:	Print Name	Signature	Affiliation	Date and Time
Received By:	Mathew V. Franco		Licensed Operator In Charge	05/28/2022 1200
Relinquished:				
Received By:				
Relinquished:				
Received By:				

Method of shipment/delivery: _____ Fed-Ex _____ Hand Delivery _____ US Mail _____ UPS _____ Courier _____ Other _____

To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY


Follow signed QAPP.

If initial first draw and follow up flush samples were collected on the same day:

- Analyze initial first draw and follow up flush samples together: Y/N _____
- Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N _____
- Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N _____

Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody

Attachment F - Pre - Sampling Water Use Certification
 (Complete for each school)

TO BE COMPLETED BY THE (Lower Cape May Regional School District) DISTRICT REPRESENTATIVE:	
School Name: Richard M. Teitleman School	
Sample collection address: 687 Route 9 Cape May, NJ 08204	
Water was last used: Time: 1800	Date: 05/27/2022
Sample commencement: Time: 0800	Date: 05/28/2022
I have read the (Lower Cape May Regional School District) Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.	
Signature 	Date: 05/28/2022
Mathew V. Franco (LOIC) License W-1 810061	



Environment Testing
America

ANALYTICAL REPORT

Eurofins Environment Testing Philadelphia, LLC
213 Witmer Road
Horsham, PA 19044-0962
Tel: (215)355-3900

Laboratory Job ID: 630-34803-1
Client Project/Site: High School - Lead

For:
Lower Cape May Regional School District
687 Route 9
Cape May, New Jersey 08204

Attn: R Olsen

Nicki Smith

Authorized for release by:
6/15/2022 7:07:32 AM

Nicki Smith, Environmental Administration Manager
(215)355-3900
Nicolette.Smith@et.eurofinsus.com

LINKS

Review your project
results through



Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015

VL = field staff performs tests under NJ State certification #06005

WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).

Nicki Smith

Nicki Smith
Environmental Administration Manager
6/15/2022 7:07:32 AM

Case Narrative

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1



Job ID: 630-34803-1

Laboratory: Eurofins Environment Testing Philadelphia, LLC

Narrative

Job Narrative
630-34803-1

Comments

No additional comments.

Receipt

The samples were received on 5/31/2022 4:43 PM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-34803-1	LCMRHS-POE-01	Drinking Water	05/28/22 08:06	05/31/22 16:43
630-34803-2	LCMRHS-WC-02	Drinking Water	05/28/22 08:08	05/31/22 16:43
630-34803-3	LCMRHS-TL-03	Drinking Water	05/28/22 08:05	05/31/22 16:43
630-34803-4	LCMRHS-IC-04	Drinking Water	05/28/22 08:06	05/31/22 16:43
630-34803-5	LCMRHS-DW-05	Drinking Water	05/28/22 08:07	05/31/22 16:43
630-34803-6	LCMRHS-KC-06	Drinking Water	05/28/22 08:09	05/31/22 16:43
630-34803-7	LCMRHS-KO-07	Drinking Water	05/28/22 08:09	05/31/22 16:43
630-34803-8	LCMRHS-FP-08	Drinking Water	05/28/22 08:07	05/31/22 16:43
630-34803-9	LCMRHS-KC-09	Drinking Water	05/28/22 08:11	05/31/22 16:43
630-34803-10	LCMRHS-FP-10	Drinking Water	05/28/22 08:11	05/31/22 16:43
630-34803-11	LCMRHS-WC-11	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-12	LCMRHS-NS-12	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-13	LCMRHS-IC-13	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-14	LCMRHS-WC-14	Drinking Water	05/28/22 08:25	05/31/22 16:43
630-34803-15	LCMRHS-WC-15	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-16	LCMRHS-TL-16	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-17	VLCMRHS-TL-17	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-18	LCMRHS-TL-19	Drinking Water	05/28/22 08:16	05/31/22 16:43
630-34803-19	LCMRHS-EC-20	Drinking Water	05/28/22 08:17	05/31/22 16:43
630-34803-20	LCMRHS-EC-21	Drinking Water	05/28/22 08:17	05/31/22 16:43
630-34803-21	LCMRHS-EC-22	Drinking Water	05/28/22 08:21	05/31/22 16:43
630-34803-22	LCMRHS-WC-23	Drinking Water	05/28/22 08:20	05/31/22 16:43
630-34803-23	LCMRHS-WC-26	Drinking Water	05/28/22 08:35	05/31/22 16:43
630-34803-24	LCMRHS-EC-27	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-25	LCMRHS-EC-28	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-26	LCMRHS-EC-29	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-27	LCMRHS-EC-30	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-28	LCMRHS-EC-31	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-29	LCMRHS-TL-33	Drinking Water	05/28/22 08:35	05/31/22 16:43
630-34803-30	LCMRHS-WC-34	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-31	LCMRHS-TL-35	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-32	LCMRHS-TL-36	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-33	LCMRHS-FP-38	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-34	LCMRHS-IC-39	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-35	LCMRHS-FP-40	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-36	LCMRHS-FP-41	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-37	LCMRHS-IC-42	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-38	LCMRHS-DW-43	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-39	LCMRHS-DW-44	Drinking Water	05/28/22 08:45	05/31/22 16:43

3

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-POE-01

Lab Sample ID: 630-34803-1

Date Collected: 05/28/22 08:06

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:53	1	UCIG

Client Sample ID: LCMRHS-WC-02

Lab Sample ID: 630-34803-2

Date Collected: 05/28/22 08:08

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:33	1	UCIG

Client Sample ID: LCMRHS-TL-03

Lab Sample ID: 630-34803-3

Date Collected: 05/28/22 08:05

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:28	1	UCIG

Client Sample ID: LCMRHS-IC-04

Lab Sample ID: 630-34803-4

Date Collected: 05/28/22 08:06

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:39	1	UCIG

Client Sample ID: LCMRHS-DW-05

Lab Sample ID: 630-34803-5

Date Collected: 05/28/22 08:07

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:41	1	UCIG

Client Sample ID: LCMRHS-KC-06

Lab Sample ID: 630-34803-6

Date Collected: 05/28/22 08:09

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	3.5		1.0	0.69	ug/L		06/10/22 01:55	1	UCIG

Client Sample ID: LCMRHS-KO-07

Lab Sample ID: 630-34803-7

Date Collected: 05/28/22 08:09

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	2.1		1.0	0.69	ug/L		06/10/22 01:47	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-FP-08

Lab Sample ID: 630-34803-8

Date Collected: 05/28/22 08:07

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:34	1	UCIG

Client Sample ID: LCMRHS-KC-09

Lab Sample ID: 630-34803-9

Date Collected: 05/28/22 08:11

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		06/09/22 20:35	1	UCIG

Client Sample ID: LCMRHS-FP-10

Lab Sample ID: 630-34803-10

Date Collected: 05/28/22 08:11

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		06/09/22 21:39	1	UCIG

Client Sample ID: LCMRHS-WC-11

Lab Sample ID: 630-34803-11

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:30	1	UCIG

Client Sample ID: LCMRHS-NS-12

Lab Sample ID: 630-34803-12

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.0		1.0	0.69	ug/L		06/09/22 21:06	1	UCIG

Client Sample ID: LCMRHS-IC-13

Lab Sample ID: 630-34803-13

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:44	1	UCIG

Client Sample ID: LCMRHS-WC-14

Lab Sample ID: 630-34803-14

Date Collected: 05/28/22 08:25

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:21	1	UCIG

4

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-WC-15

Lab Sample ID: 630-34803-15

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:44	1	UCIG

Client Sample ID: LCMRHS-TL-16

Lab Sample ID: 630-34803-16

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.84	J	1.0	0.69	ug/L		06/09/22 21:20	1	UCIG

Client Sample ID: VLCMRHS-TL-17

Lab Sample ID: 630-34803-17

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		06/09/22 18:34	1	UCIG

Client Sample ID: LCMRHS-TL-19

Lab Sample ID: 630-34803-18

Date Collected: 05/28/22 08:16

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		06/09/22 21:03	1	UCIG

Client Sample ID: LCMRHS-EC-20

Lab Sample ID: 630-34803-19

Date Collected: 05/28/22 08:17

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.91	J	1.0	0.69	ug/L		06/10/22 02:28	1	UCIG

Client Sample ID: LCMRHS-EC-21

Lab Sample ID: 630-34803-20

Date Collected: 05/28/22 08:17

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:46	1	UCIG

Client Sample ID: LCMRHS-EC-22

Lab Sample ID: 630-34803-21

Date Collected: 05/28/22 08:21

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	23		1.0	0.69	ug/L		06/09/22 21:01	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-WC-23

Lab Sample ID: 630-34803-22

Date Collected: 05/28/22 08:20

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 18:36	1	UCIG

Client Sample ID: LCMRHS-WC-26

Lab Sample ID: 630-34803-23

Date Collected: 05/28/22 08:35

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:04	1	UCIG

Client Sample ID: LCMRHS-EC-27

Lab Sample ID: 630-34803-24

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.88	J	1.0	0.69	ug/L		06/09/22 21:08	1	UCIG

Client Sample ID: LCMRHS-EC-28

Lab Sample ID: 630-34803-25

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.98	J	1.0	0.69	ug/L		06/09/22 20:07	1	UCIG

Client Sample ID: LCMRHS-EC-29

Lab Sample ID: 630-34803-26

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:56	1	UCIG

Client Sample ID: LCMRHS-EC-30

Lab Sample ID: 630-34803-27

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 02:30	1	UCIG

Client Sample ID: LCMRHS-EC-31

Lab Sample ID: 630-34803-28

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:17	1	UCIG

4

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-TL-33

Lab Sample ID: 630-34803-29

Date Collected: 05/28/22 08:35

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:20	1	UCIG

Client Sample ID: LCMRHS-WC-34

Lab Sample ID: 630-34803-30

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:19	1	UCIG

Client Sample ID: LCMRHS-TL-35

Lab Sample ID: 630-34803-31

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 18:53	1	UCIG

Client Sample ID: LCMRHS-TL-36

Lab Sample ID: 630-34803-32

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		06/09/22 19:29	1	UCIG

Client Sample ID: LCMRHS-FP-38

Lab Sample ID: 630-34803-33

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:52	1	UCIG

Client Sample ID: LCMRHS-IC-39

Lab Sample ID: 630-34803-34

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 23:33	1	UCIG

Client Sample ID: LCMRHS-FP-40

Lab Sample ID: 630-34803-35

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.69	J	1.0	0.69	ug/L		06/09/22 19:08	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-FP-41

Lab Sample ID: 630-34803-36

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.98	J	1.0	0.69	ug/L		06/09/22 21:42	1	UCIG

Client Sample ID: LCMRHS-IC-42

Lab Sample ID: 630-34803-37

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.90	J	1.0	0.69	ug/L		06/10/22 00:35	1	UCIG

Client Sample ID: LCMRHS-DW-43

Lab Sample ID: 630-34803-38

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:37	1	UCIG

Client Sample ID: LCMRHS-DW-44

Lab Sample ID: 630-34803-39

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:57	1	UCIG



Environment Testing
America

ANALYTICAL REPORT

Eurofins Environment Testing Philadelphia, LLC
213 Witmer Road
Horsham, PA 19044-0962
Tel: (215)355-3900

Laboratory Job ID: 630-34803-1
Client Project/Site: High School - Lead


For:
Lower Cape May Regional School District
687 Route 9
Cape May, New Jersey 08204

Attn: R Olsen

Nicki Smith

Authorized for release by:
6/15/2022 7:07:32 AM

Nicki Smith, Environmental Administration Manager
(215)355-3900
Nicolette.Smith@et.eurofinsus.com



..... LINKS

Review your project
results through
 my EOL

Have a Question?
 Ask The Expert

Visit us at:
www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015

VL = field staff performs tests under NJ State certification #06005

WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).

Nicki Smith

Nicki Smith
Environmental Administration Manager
6/15/2022 7:07:32 AM

Case Narrative

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1



Job ID: 630-34803-1

Laboratory: Eurofins Environment Testing Philadelphia, LLC

Narrative

Job Narrative
630-34803-1

Comments

No additional comments.

Receipt

The samples were received on 5/31/2022 4:43 PM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

3

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-34803-1	LCMRHS-POE-01	Drinking Water	05/28/22 08:08	05/31/22 16:43
630-34803-2	LCMRHS-WC-02	Drinking Water	05/28/22 08:08	05/31/22 16:43
630-34803-3	LCMRHS-TL-03	Drinking Water	05/28/22 08:05	05/31/22 16:43
630-34803-4	LCMRHS-IC-04	Drinking Water	05/28/22 08:06	05/31/22 16:43
630-34803-5	LCMRHS-DW-05	Drinking Water	05/28/22 08:07	05/31/22 16:43
630-34803-6	LCMRHS-KC-06	Drinking Water	05/28/22 08:09	05/31/22 16:43
630-34803-7	LCMRHS-KO-07	Drinking Water	05/28/22 08:09	05/31/22 16:43
630-34803-8	LCMRHS-FP-08	Drinking Water	05/28/22 08:07	05/31/22 16:43
630-34803-9	LCMRHS-KC-09	Drinking Water	05/28/22 08:11	05/31/22 16:43
630-34803-10	LCMRHS-FP-10	Drinking Water	05/28/22 08:11	05/31/22 16:43
630-34803-11	LCMRHS-WC-11	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-12	LCMRHS-NS-12	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-13	LCMRHS-IC-13	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-14	LCMRHS-WC-14	Drinking Water	05/28/22 08:25	05/31/22 16:43
630-34803-15	LCMRHS-WC-15	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-16	LCMRHS-TL-16	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-17	VLCMRHS-TL-17	Drinking Water	05/28/22 08:15	05/31/22 16:43
630-34803-18	LCMRHS-TL-19	Drinking Water	05/28/22 08:16	05/31/22 16:43
630-34803-19	LCMRHS-EC-20	Drinking Water	05/28/22 08:17	05/31/22 16:43
630-34803-20	LCMRHS-EC-21	Drinking Water	05/28/22 08:17	05/31/22 16:43
630-34803-21	LCMRHS-EC-22	Drinking Water	05/28/22 08:21	05/31/22 16:43
630-34803-22	LCMRHS-WC-23	Drinking Water	05/28/22 08:20	05/31/22 16:43
630-34803-23	LCMRHS-WC-26	Drinking Water	05/28/22 08:35	05/31/22 16:43
630-34803-24	LCMRHS-EC-27	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-25	LCMRHS-EC-28	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-26	LCMRHS-EC-29	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-27	LCMRHS-EC-30	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-28	LCMRHS-EC-31	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-29	LCMRHS-TL-33	Drinking Water	05/28/22 08:35	05/31/22 16:43
630-34803-30	LCMRHS-WC-34	Drinking Water	05/28/22 08:30	05/31/22 16:43
630-34803-31	LCMRHS-TL-35	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-32	LCMRHS-TL-36	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-33	LCMRHS-FP-38	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-34	LCMRHS-IC-39	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-35	LCMRHS-FP-40	Drinking Water	05/28/22 08:40	05/31/22 16:43
630-34803-36	LCMRHS-FP-41	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-37	LCMRHS-IC-42	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-38	LCMRHS-DW-43	Drinking Water	05/28/22 08:45	05/31/22 16:43
630-34803-39	LCMRHS-DW-44	Drinking Water	05/28/22 08:45	05/31/22 16:43

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-POE-01

Lab Sample ID: 630-34803-1

Date Collected: 05/28/22 08:06

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	ND		1.0	0.69	ug/L		06/10/22 01:53	1	UCIG	

Client Sample ID: LCMRHS-WC-02

Lab Sample ID: 630-34803-2

Date Collected: 05/28/22 08:08

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	ND		1.0	0.69	ug/L		06/09/22 20:33	1	UCIG	

Client Sample ID: LCMRHS-TL-03

Lab Sample ID: 630-34803-3

Date Collected: 05/28/22 08:05

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	ND		1.0	0.69	ug/L		06/09/22 20:28	1	UCIG	

Client Sample ID: LCMRHS-IC-04

Lab Sample ID: 630-34803-4

Date Collected: 05/28/22 08:06

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	ND		1.0	0.69	ug/L		06/10/22 00:39	1	UCIG	

Client Sample ID: LCMRHS-DW-05

Lab Sample ID: 630-34803-5

Date Collected: 05/28/22 08:07

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	ND		1.0	0.69	ug/L		06/10/22 00:41	1	UCIG	

Client Sample ID: LCMRHS-KC-06

Lab Sample ID: 630-34803-6

Date Collected: 05/28/22 08:09

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	3.5		1.0	0.69	ug/L		06/10/22 01:55	1	UCIG	

Client Sample ID: LCMRHS-KO-07

Lab Sample ID: 630-34803-7

Date Collected: 05/28/22 08:09

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Lead	2.1		1.0	0.69	ug/L		06/10/22 01:47	1	UCIG	

4

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-FP-08

Lab Sample ID: 630-34803-8

Date Collected: 05/28/22 08:07

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:34	1	UCIG

Client Sample ID: LCMRHS-KC-09

Lab Sample ID: 630-34803-9

Date Collected: 05/28/22 08:11

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.3		1.0	0.69	ug/L		06/09/22 20:35	1	UCIG

Client Sample ID: LCMRHS-FP-10

Lab Sample ID: 630-34803-10

Date Collected: 05/28/22 08:11

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		06/09/22 21:39	1	UCIG

Client Sample ID: LCMRHS-WC-11

Lab Sample ID: 630-34803-11

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:30	1	UCIG

Client Sample ID: LCMRHS-NS-12

Lab Sample ID: 630-34803-12

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.0		1.0	0.69	ug/L		06/09/22 21:06	1	UCIG

Client Sample ID: LCMRHS-IC-13

Lab Sample ID: 630-34803-13

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:44	1	UCIG

Client Sample ID: LCMRHS-WC-14

Lab Sample ID: 630-34803-14

Date Collected: 05/28/22 08:25

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:21	1	UCIG

4

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-WC-15

Lab Sample ID: 630-34803-15

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:44	1	UCIG

Client Sample ID: LCMRHS-TL-16

Lab Sample ID: 630-34803-16

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.84	J	1.0	0.69	ug/L		06/09/22 21:20	1	UCIG

Client Sample ID: VLCMRHS-TL-17

Lab Sample ID: 630-34803-17

Date Collected: 05/28/22 08:15

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.1		1.0	0.69	ug/L		06/09/22 18:34	1	UCIG

Client Sample ID: LCMRHS-TL-19

Lab Sample ID: 630-34803-18

Date Collected: 05/28/22 08:16

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		06/09/22 21:03	1	UCIG

Client Sample ID: LCMRHS-EC-20

Lab Sample ID: 630-34803-19

Date Collected: 05/28/22 08:17

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.91	J	1.0	0.69	ug/L		06/10/22 02:28	1	UCIG

Client Sample ID: LCMRHS-EC-21

Lab Sample ID: 630-34803-20

Date Collected: 05/28/22 08:17

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:46	1	UCIG

Client Sample ID: LCMRHS-EC-22

Lab Sample ID: 630-34803-21

Date Collected: 05/28/22 08:21

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	23		1.0	0.69	ug/L		06/09/22 21:01	1	UCIG

4

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-WC-23

Lab Sample ID: 630-34803-22

Date Collected: 05/28/22 08:20

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 18:36	1	UCIG

Client Sample ID: LCMRHS-WC-26

Lab Sample ID: 630-34803-23

Date Collected: 05/28/22 08:35

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 21:04	1	UCIG

Client Sample ID: LCMRHS-EC-27

Lab Sample ID: 630-34803-24

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.88	J	1.0	0.69	ug/L		06/09/22 21:08	1	UCIG

Client Sample ID: LCMRHS-EC-28

Lab Sample ID: 630-34803-25

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.98	J	1.0	0.69	ug/L		06/09/22 20:07	1	UCIG

Client Sample ID: LCMRHS-EC-29

Lab Sample ID: 630-34803-26

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:56	1	UCIG

Client Sample ID: LCMRHS-EC-30

Lab Sample ID: 630-34803-27

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 02:30	1	UCIG

Client Sample ID: LCMRHS-EC-31

Lab Sample ID: 630-34803-28

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:17	1	UCIG

Client Sample Results

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-TL-33

Lab Sample ID: 630-34803-29

Date Collected: 05/28/22 08:35

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:20	1	UCIG

Client Sample ID: LCMRHS-WC-34

Lab Sample ID: 630-34803-30

Date Collected: 05/28/22 08:30

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 19:19	1	UCIG

Client Sample ID: LCMRHS-TL-35

Lab Sample ID: 630-34803-31

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 18:53	1	UCIG

Client Sample ID: LCMRHS-TL-36

Lab Sample ID: 630-34803-32

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	1.2		1.0	0.69	ug/L		06/09/22 19:29	1	UCIG

Client Sample ID: LCMRHS-FP-38

Lab Sample ID: 630-34803-33

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 01:52	1	UCIG

Client Sample ID: LCMRHS-IC-39

Lab Sample ID: 630-34803-34

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 23:33	1	UCIG

Client Sample ID: LCMRHS-FP-40

Lab Sample ID: 630-34803-35

Date Collected: 05/28/22 08:40

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.69	J	1.0	0.69	ug/L		06/09/22 19:08	1	UCIG

4

Client Sample Results

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-FP-41

Lab Sample ID: 630-34803-36

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.98	J	1.0	0.69	ug/L		06/09/22 21:42	1	UCIG

Client Sample ID: LCMRHS-IC-42

Lab Sample ID: 630-34803-37

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.90	J	1.0	0.69	ug/L		06/10/22 00:35	1	UCIG

Client Sample ID: LCMRHS-DW-43

Lab Sample ID: 630-34803-38

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/10/22 00:37	1	UCIG

Client Sample ID: LCMRHS-DW-44

Lab Sample ID: 630-34803-39

Date Collected: 05/28/22 08:45

Matrix: Drinking Water

Date Received: 05/31/22 16:43

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/09/22 20:57	1	UCIG

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-POE-01

Lab Sample ID: 630-34803-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-02

Lab Sample ID: 630-34803-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-TL-03

Lab Sample ID: 630-34803-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-IC-04

Lab Sample ID: 630-34803-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-DW-05

Lab Sample ID: 630-34803-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-KC-06

Lab Sample ID: 630-34803-6

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	3.5		ug/L	15.4	1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-KO-07

Lab Sample ID: 630-34803-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	2.1		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-FP-08

Lab Sample ID: 630-34803-8

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-KC-09

Lab Sample ID: 630-34803-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.3		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-FP-10

Lab Sample ID: 630-34803-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.1		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-11

Lab Sample ID: 630-34803-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRHS-NS-12

Lab Sample ID: 630-34803-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL Limit	RL	Method	Prep Type
Lead	1.0		ug/L	15.4	1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-IC-13

Lab Sample ID: 630-34803-13

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-14

Lab Sample ID: 630-34803-14

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-15

Lab Sample ID: 630-34803-15

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-TL-16

Lab Sample ID: 630-34803-16

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.84	J	ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: VLCMRHS-TL-17

Lab Sample ID: 630-34803-17

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.1		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-TL-19

Lab Sample ID: 630-34803-18

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.2		ug/L	15.4		1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-EC-20

Lab Sample ID: 630-34803-19

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.91	J	ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-21

Lab Sample ID: 630-34803-20

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-22

Lab Sample ID: 630-34803-21

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	23		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-23

Lab Sample ID: 630-34803-22

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-26

Lab Sample ID: 630-34803-23

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-27

Lab Sample ID: 630-34803-24

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.88	J	ug/L	15.4		1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-EC-28

Lab Sample ID: 630-34803-25

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.98	J	ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-29

Lab Sample ID: 630-34803-26

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-30

Lab Sample ID: 630-34803-27

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-EC-31

Lab Sample ID: 630-34803-28

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-TL-33

Lab Sample ID: 630-34803-29

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-WC-34

Lab Sample ID: 630-34803-30

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-TL-35

Lab Sample ID: 630-34803-31

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-TL-36

Lab Sample ID: 630-34803-32

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	1.2		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-FP-38

Lab Sample ID: 630-34803-33

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-IC-39

Lab Sample ID: 630-34803-34

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-FP-40

Lab Sample ID: 630-34803-35

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.69	J	ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-FP-41

Lab Sample ID: 630-34803-36

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.98	J	ug/L	15.4		1.0	200.8	Total/NA

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Client Sample ID: LCMRHS-IC-42

Lab Sample ID: 630-34803-37

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	0.90	J	ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-DW-43

Lab Sample ID: 630-34803-38

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

Client Sample ID: LCMRHS-DW-44

Lab Sample ID: 630-34803-39

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Lead	ND		ug/L	15.4		1.0	200.8	Total/NA

5

Accreditation/Certification and Definitions Summary

Client: Lower Cape May Regional School District
 Project/Site: High School - Lead

Job ID: 630-34803-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-22

Qualifiers

Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
π	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Method Summary

Client: Lower Cape May Regional School District
Project/Site: High School - Lead

Job ID: 630-34803-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION AND FLUORIDE CONCENTRATION FORM

School Project Manager & Contact Information

NAME: Roy Olsen
 PHONE: (609)-884-3475 Ext:220

NAME: E
 ADDRESS
 LAB MGR
 LAB QA D



630-34803 Chain of Custody

School Facility Information

SCHOOL FACILITY NAME: Lower Cape May Regional School District
 BLDG ID: Lower Cape May Regional High School
 BLDG ADDRESS: 687 Route 9 Cape May, NJ 08204
 CONTACT NAME & PHONE: Mathew Franco (609)-780-5113

MATRIX: DRINKING WATER Y/N
 SAMPLE TYPE: GRAB Y/N

SAMPLER NAME: Mathew V. Franco AFFILIATION: Licensed Operator In Charge

DATE OF SAMPLING: 05/28/2022

SAMPLE DATA FOR LEAD ANALYSIS

Sample Description ID. (ID must match container)

Field Sample ID #	Sample Location ID (if different)	Check if Filter Present	Check if Flush	Time of Collection (military time)	# of Sample Bottles	pH-Z	Observations
1	LCMRHS-POE-01			0806	1		
2	LCMRHS-WC-02			0808	1		
3	LCMRHS-TL-03	YES		0805	1		
4	LCMRHS-IC-04	YES		0804	1		
5	LCMRHS-DW-05	YES		0807	1		
6	LCMRHS-KC-06			0809	1		
7	LCMRHS-KO-07			0809	1		
8	LCMRHS-PP-08			0807	1		
9	LCMRHS-KC-09			0811	1		
10	LCMRHS-PP-10			0811	1		
11	LCMRHS-WC-11			0845	1		
12	LCMRHS-NS-12			0815	1		
13	LCMRHS-IC-13	YES		0815	1		
14	LCMRHS-WC-14	YES		0825	1		
15	LCMRHS-WC-15	YES		0815	1		
16	LCMRHS-TL-16			0815	1		

All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃):

Relinquished:	Print Name	Sign Stamp	Affiliation	Date and Time
Received By:	Mathew V. Franco	<i>Mathew Franco</i>	Licensed Operator In Charge	05/28/2022 1200
Relinquished:	Jane Glass	<i>Jane Glass</i>	Endorsing Q.C. Standard	5/28/22 14:00
Received By:				
Relinquished:				
Received By:				

Method of shipment/delivery: Fed-Ex ___ Hand Delivery ___ US Mail ___ UPS ___ Courier ___ Other: ___
 To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY

Follow signed QAPP.

If initial first draw and follow up flush samples were collected on the same day:

- Analyze initial first draw and follow up flush samples together: Y/N
- Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N
- Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N

Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody



Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

School Project Manager & Contact Information

NAME: Roy Olsen
 PHONE: (609)-884-3475 Ext:220

Laboratory Information

NAME: Eurofins QC, Inc.
 ADDRESS & PHONE:
 LAB MGR:
 LAB QA DIRECTOR:

School Facility Information

SCHOOL FACILITY NAME: Lower Cape May Regional School District
 BLDG ID: Lower Cape May Regional High School
 BLDG ADDRESS: 687 Route 9 Cape May, NJ 08204
 CONTACT NAME & PHONE: Matthew Franco (609)-780-5113
 SAMPLE NAME: Matthew V. Franco AFFILIATION: Licensed Operator in Charge

MATRIX: DRINKING WATER Y/N _____
 SAMPLE TYPE: GRAB Y/N _____

DATE OF SAMPLING: 05/28/2022

Field Sample ID #	Sample Location ID (if different)	Check if Filter Present	Check if Flush	Time of Collection (military time)	# of Sample Bottles	pH<2	Observations
17	LCMRHS-TL-17			0815	1		
19	LCMRHS-TL-19			0816	1		
20	LCMRHS-EC-20			0817	1		
21	LCMRHS-EC-21			0817	1		
22	LCMRHS-EC-22			0821	1		
23	LCMRHS-WC-23			0820	1		
26	LCMRHS-WC-26			0835	1		
27	LCMRHS-EC-27			0830	1		
28	LCMRHS-EC-28			0830	1		
29	LCMRHS-EC-29			0830	1		
30	LCMRHS-EC-30			0830	1		
31	LCMRHS-EC-31			0830	1		

All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃):

Relinquished:	Print Name	Sign Name	Affiliation	Date and Time
Received By:	Matthew V. Franco		Licensed operator in Charge	05/28/2022 1200
Relinquished:				
Received By:				
Relinquished:				
Received By:				

Method of shipment/delivery: _____ Fac-Ex _____ Hand Delivery _____ US Mail _____ UPS _____ Courier _____ Other _____
 To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY

Follow signed QAPP.
 If initial first draw and follow up flush samples were collected on the same day:
 1. Analyze initial first draw and follow up flush samples together: Y/N _____
 2. Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N _____
 3. Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N _____
 Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody



Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

School Project Manager & Contact Information

NAME: Roy Olsen
 PHONE: (609)-884-3475 Ext:220

Laboratory Information

NAME: Eurofins Qc, Inc.
 ADDRESS & PHONE:
 LAB MGR:
 LAB QA DIRECTOR:

School Facility Information

SCHOOL FACILITY NAME: Lower Cape May Regional School District
 BLDG ID: Lower Cape May Regional High School
 BLDG ADDRESS: 687 Route 9 Cape May, NJ 08204
 CONTACT NAME & PHONE: Mathew Franco (609)-780-5113

MATRIX: DRINKING WATER Y/N _____
 SAMPLE TYPE: GRAB Y/N _____

DATE OF SAMPLING: 05/28/2022

AFFILIATION: Licensed Operator in Charge

SAMPLE NAME: Mathew V. Franco

Field Sample ID #	Sample Location ID (if different)	Check if Filter Present	Check if Flush	Time of Collection (military time)	# of Sample Bottles	pH<2	Observations
33	LCMRHS-TL-33			0835	1		
34	LCMRHS-WC-34			0830	1		
35	LCMRHS-TL-35			0840	1		
36	LCMRHS-TL-36			0840	1		
38	LCMRHS-FP-38			0840	1		
39	LCMRHS-IC-39		YES	0840	1		
40	LCMRHS-FP-40			0840	1		
41	LCMRHS-FP-41			0845	1		
42	LCMRHS-IC-42		YES	0845	1		
43	LCMRHS-DW-43			0845	1		
44	LCMRHS-DW-44			0845	1		

All containers are pre-cleaned 250 ml wide mouth plastic bottles.

Date and Time Range of initial preservation of sample(s) (conc. HNO₃):

Print Name	Sign Name	Affiliation	Date and Time
Mathew V. Franco		Licensed operator in Charge	05/28/2022 1200

Method of shipment/delivery: _____ Fed-Ex _____ Hand Delivery _____ US Mail _____ UPS _____ Courier _____ Other _____


To be completed by School Facility:

INSTRUCTIONS TO THE LABORATORY

Follow signed QAPP.
 If initial first draw and follow up flush samples were collected on the same day:
 1. Analyze initial first draw and follow up flush samples together: Y/N _____
 2. Analyze initial first draw samples only and analyze follow up flush samples upon instruction from School Project Manager: Y/N _____
 3. Analyze follow up flush samples when the corresponding initial first draw results exceed 15µg/L without contacting the School Project Manager: Y/N _____
 Comments: Provide Laboratory Data Report (LDR) Package, Excel Spreadsheet, and Chain of Custody



Attachment F - Pre - Sampling Water Use Certification
(Complete for each school)

TO BE COMPLETED BY THE (Lower Cape May Regional School District) DISTRICT REPRESENTATIVE:	
School Name: Lower Cape May Regional High School	
Sample collection address: 687 Route 9 Cape May, NJ 08204	
Water was last used: Time: 1800	Date: 05/27/2022
Sample commencement: Time: 0800	Date: 05/28/2022
I have read the (Lower Cape May Regional School District) Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.	
Signature: 	Date: 05/28/2022
Matthew V. Franco (LOIC) License W-1 810061	



Eurofins Environment Testing Philadelphia
 213 Wilmer Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900 Fax: 888-785-8567

Chain of Custody Record



eurofins Environment Testing America

Client Information (Sub Contract Lab)		Sampler:	Lab PM Smith, Nicki	Corner Tracking Not(s):	COC No: 830-7838.1					
Client Contact Shipping/Receiving		Phone:	E-Mail: Nicolata.Smith@eurofins.com	State of Origin: New Jersey	Page: Page 1 of 6					
Company: Eurofins Lancaster Laboratories Environm		Accreditations Required (See rctc) NELAP - New Jersey			Job #: 630-34803-1					
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601 Phone: 717-656-2300(Tel) Email:		Due Date Requested: 6/13/2022	Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA Other:					
Project Name: High School - Lead Site: Lower Cape May High School		TAT Requested (days):	2003_SOWAUNT_NO_Prep (MOD) Pb only		Other: M - Hexane N - None O - AsH2O2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4-5 X - Trizma Z - other (specify)					
PO #:		Project #: 63002692	Total Number of Containers		Special Instructions/Note:					
WO #:		SSOW#:								
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (SPRINKLER, DOMESTIC, INDUSTRIAL, AQA)	Fluid Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Total Number of Containers		Special Instructions/Note:
				Preservation Code:						
LCMRHS-POE-01 (630-34803-1)		5/28/22	08:06 Eastern	Drinking Water			X	1		
LCMRHS-WC-02 (630-34803-2)		5/28/22	08:08 Eastern	Drinking Water			X	1		
LCMRHS-TL-03 (630-34803-3)		5/28/22	08:05 Eastern	Drinking Water			X	1		
LCMRHS-IC-04 (630-34803-4)		5/28/22	08:06 Eastern	Drinking Water			X	1		
LCMRHS-DW-05 (630-34803-5)		5/28/22	08:07 Eastern	Drinking Water			X	1		
LCMRHS-KC-06 (630-34803-6)		5/28/22	08:09 Eastern	Drinking Water			X	1		
LCMRHS-KO-07 (630-34803-7)		5/28/22	08:09 Eastern	Drinking Water			X	1		
LCMRHS-FP-08 (630-34803-8)		5/28/22	08:07 Eastern	Drinking Water			X	1		
LCMRHS-KC-09 (630-34803-9)		6/28/22	08:11 Eastern	Drinking Water			X	1		
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>										
Possible Hazard Identification					Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)					Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:										
Empty Kit Relinquished by:		Date:	Time:	Method of Shipment:						
Relinquished by: _____		Date/Time: 5/31/22 2100	Company: PSC	Received by: ER6677 Dragonlance		Date/Time: 5/31/22 2305	Company: ELJET			
Relinquished by: _____		Date/Time:	Company:	Received by: _____		Date/Time:	Company:			
Relinquished by: _____		Date/Time:	Company:	Received by: _____		Date/Time:	Company:			
Custody Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Custody Seal No.: ER6677 Dragonlance		Cooler Temperature(s) °C and Other Remarks: 23.5, 23.4						

Ver. 06/08/2021

Eurofins Environment Testing Philadelphia
 213 Wilmer Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900 Fax: 888-785-8567

Chain of Custody Record


eurofins Environment Testing America

Client Information (Sub Contract Lab)		Sampler:	Lab PM Smith, Nickl	Carrier Tracking No(s)	COC No: 630-7838.4
Client Contact: Shipping/Receiving		Phone:	E-Mail: Nicolette.Smith@et.eurofins.com	State of Origin: New Jersey	Page: Page 4 of 5
Company: Eurofins Lancaster Laboratories Environm		Accreditations Required (See note): NELAP - New Jersey			Job #: 630-34803-1
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601		Due Date Requested: 6/13/2022	Analysis Requested		Preservation Codes: A - HCL M - Hexane B - NaOH N - Hexane C - Zn Acetate Q - AsH3O2 D - Nitric Acid P - Na2O4S E - NaHSO4 R - Na2S2O3 F - HClO4 S - H2SO4 G - Ascorbic Acid T - TSP Dodecahydrate H - Ice U - Acetone I - DI Water V - HCl J - EDTA W - pH 4.5 K - EDTA X - Trizma L - EDTA Z - other (specify)
Phone: 717-656-2300(Tel) FAX:		TAT Requested (days):			
Project Name: High School - Lead		Project #: 63002692	Total Number of Containers		Other:
Site: Lower Cape May High School		SSOW#:			
Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (Inorganic, Organic, SW-846, etc.)	Special Instructions/Note:
				Field Filtered Sample (Yes or No)	
				Perform MS/MSO (Yes or No)	
				200g, SOLVANT, NO Prep (MOD) Pk only	
LCMRHS-EC-31 (630-34803-28)	5/28/22	08:30 Eastern	Drinking Water		X
LCMRHS-TL-33 (630-34803-29)	5/28/22	08:35 Eastern	Drinking Water		X
LCMRHS-WC-34 (630-34803-30)	5/28/22	08:30 Eastern	Drinking Water		X
LCMRHS-TL-35 (630-34803-31)	5/28/22	08:40 Eastern	Drinking Water		X
LCMRHS-TL-36 (630-34803-32)	5/28/22	08:40 Eastern	Drinking Water		X
LCMRHS-FP-38 (630-34803-33)	5/28/22	08:40 Eastern	Drinking Water		X
LCMRHS-IC-39 (630-34803-34)	5/28/22	08:40 Eastern	Drinking Water		X
LCMRHS-FP-40 (630-34803-35)	5/28/22	08:40 Eastern	Drinking Water		X
LCMRHS-FP-41 (630-34803-36)	5/28/22	08:45 Eastern	Drinking Water		X
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/testing/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>					
Possible Hazard Identification			Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		
Unconfirmed			<input type="checkbox"/> Return To Client <input checked="" type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months		
Deliverable Requested: I, II, III, IV, Other (specify)		Primary Deliverable Rank: 1	Special Instructions/QC Requirements:		
Empty Kit Relinquished by:	Date:	Time:	Method of Shipment:		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Custody Seal No.: ER6677	DragonLance	Cooler Temperature(s) °C and °F: 23.5, 23.4	Date: 6/15/22 23:07 Company: ETL/ET	

8

Eurofins Environment Testing Philadelphia
 213 Wilmer Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900 Fax: 888-785-8567

Chain of Custody Record



Client Information (Sub Contract Lab)		Sampler:	Lab PM: Smith, Nicki	Carrier Tracking No(s):	COC No: 630-7838 5					
Client Contact Shipping/Receiving		Phone:	E-Mail: Nicolette.Smith@eurofins.com	State of Origin: New Jersey	Page: Page 6 of 6					
Company: Eurofins Lancaster Laboratories Environm		Accreditations Required (See note) NELAP - New Jersey			Job #: 630-34803-1					
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601 Phone: 717-656-2300(Tel) Email:		Due Date Requested: 8/13/2022	Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - NaHSO4 F - MeOH G - Amchlor H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - AsH2O2 P - Na2O4S Q - Na2SO3 R - Na2S2O3 S - H2SO4 T - TSP Dodecahydrate U - Acetone V - MCAA W - pH 4.5 Y - Triana Z - other (specify)					
Project Name: High School - Lead Site: Lower Cape May High School		TAT Requested (days):	PO #:	WO #:	Project #: 63002692 SSOW#:					
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (W=water, S=solid, O=organic, I=inorganic, A=air)	Field Filled Sample (Yes or No)	Permitted Method (Yes or No)	200 µg SWAN/MTL, ND, Prep (MDD) Pts only	Total Number of Containers	Special Instructions/Note:
LCMRHS-IC-42 (630-34803-37)		5/28/22	08:45 Eastern	Drinking Water	Drinking Water	X			1	
LCMRHS-DW-43 (630-34803-38)		5/28/22	08:45 Eastern	Drinking Water	Drinking Water	X			1	
LCMRHS-DW-44 (630-34803-39)		5/28/22	08:45 Eastern	Drinking Water	Drinking Water	X			1	
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>										
Possible Hazard Identification					Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)					
Unconfirmed					<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)					Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:										
Empty Kit Relinquished by:		Date:	Time:	Method of Shipment:						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:					
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:					
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:					
Custody Seals Intact:	Custody Seal No.:	ER6677		Pregnance		Cooler Temperature and Other Remarks:		23.5, 23.4		
<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								EUCET		

Ver: 06/08/2021

8



Environment Testing
America

ANALYTICAL REPORT

Eurofins Environment Testing Philadelphia, LLC
213 Witmer Road
Horsham, PA 19044-0962
Tel: (215)355-3900

Laboratory Job ID: 630-35746-1
Client Project/Site: Administration Building - Lead

For:
Lower Cape May Regional School District
687 Route 9
Cape May, New Jersey 08204

Attn: R Olsen

Nicki Smith

Authorized for release by:
6/21/2022 10:57:32 AM

Nicki Smith, Environmental Administration Manager
(215)355-3900
Nicolette.Smith@et.eurofinsus.com

LINKS

Review your project
results through



Have a Question?




Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.



Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015

VL = field staff performs tests under NJ State certification #06005

WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).

Nicki Smith

Nicki Smith
Environmental Administration Manager
6/21/2022 10:57:32 AM

Case Narrative

Client: Lower Cape May Regional School District
Project/Site: Administration Building - Lead

Job ID: 630-35746-1



Job ID: 630-35746-1

Laboratory: Eurofins Environment Testing Philadelphia, LLC

Narrative

Job Narrative
630-35746-1

Receipt

The samples were received on 5/31/2022 2:00 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice.

Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

Sample Summary

Client: Lower Cape May Regional School District
Project/Site: Administration Building - Lead

Job ID: 630-35746-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-35746-1	LCMRADM-POE-29	Drinking Water	05/28/22 09:30	05/31/22 14:00
630-35746-2	LCMRADM-TL-30	Drinking Water	05/28/22 09:31	05/31/22 14:00

3

Client Sample Results

Client: Lower Cape May Regional School District
Project/Site: Administration Building - Lead

Job ID: 630-35746-1

Client Sample ID: LCMRADM-POE-29

Lab Sample ID: 630-35746-1

Date Collected: 05/28/22 09:30

Matrix: Drinking Water

Date Received: 05/31/22 14:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/17/22 22:01	1	S4PD

Client Sample ID: LCMRADM-TL-30

Lab Sample ID: 630-35746-2

Date Collected: 05/28/22 09:31

Matrix: Drinking Water

Date Received: 05/31/22 14:00

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	ND		1.0	0.69	ug/L		06/17/22 22:02	1	S4PD

4

Action Limit Summary

Client: Lower Cape May Regional School District
Project/Site: Administration Building - Lead

Job ID: 630-35746-1

Client Sample ID: LCMRADM-POE-29

Lab Sample ID: 630-35746-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

Client Sample ID: LCMRADM-TL-30

Lab Sample ID: 630-35746-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Lead	ND		ug/L	15.4	1.0	200.8	Total/NA

5

Accreditation/Certification and Definitions Summary

Client: Lower Cape May Regional School District
 Project/Site: Administration Building - Lead

Job ID: 630-35746-1

Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-22

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

Method Summary

Client: Lower Cape May Regional School District
Project/Site: Administration Building - Lead

Job ID: 630-35746-1

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:


EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

7

Attachment F - Pre -- Sampling Water Use Certification
(Complete for each school)

TO BE COMPLETED BY THE (Lower Cape May Regional School District) DISTRICT REPRESENTATIVE:	
School Name: Administration Building	
Sample collection address:	687 Route 9 Cape May, NJ 08204
Water was last used:	Time: 1800 Date: 05/27/2022
Sample commencement:	Time: 0800 Date: 05/27/2022
I have read the (INSERT SCHOOL DISTRICT NAME) Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.	
Signature	 05/28/2022
	Date

Eurofins Environment Testing Philadelphia
 213 Witmer Road
 Horsham, PA 19044-0962
 Phone: 215-355-3900 Fax: 888-785-8567

Chain of Custody Record



eurofins Environment Testing
 America

Client Information (Sub Contract Lab)		Sampler:	Lab PM Smith, Nicki	Carrier Tracking No(s)	COC No: 830-7907.1	
Client Contact Shipping/Receiving		Phone:	E-Mail Nicole@eurofins.com	State of Origin: New Jersey	Pages: Page 1 of 1	
Company: Eurofins Lancaster Laboratories Environm		Accreditations Required (See note) NELAP - New Jersey			Job #: 6300-35746-1	
Address: 2425 New Holland Pike, City: Lancaster State, Zip: PA, 17601 Phone: 717-656-2300(Tel) Email		Due Date Requested: 6/21/2022	Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - Nitric Acid F - MeOH G - Ammonia H - Ascorbic Acid I - Ice J - DI Water K - EDTA L - EDA M - Hexane N - None O - As ₂ O ₃ P - Na ₂ O ₄ S Q - Na ₂ SO ₃ R - Na ₂ S ₂ O ₃ S - H ₂ SO ₄ T - TSP Dodecahydrate U - Acetone V - JACAA W - pH 4-5 Y - Triana Z - other (specify) Other:	
Project Name: Administration Building - Lead Site: Lower Cape May High School		TAT Requested (days):				
PO #		Project #: 63002892	Perform MS/MSD (Yes or No)		Total Number of Containers	
W/O #		SSOW#:	2004_SWAVANTL_NO_Prep (MSD) No only			
Sample Identification - Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (Inorganic, Organic, Other/Trace, AA#)	Special Instructions/Note:
					Preservation Code:	
LCMRADM-POE-29 (630-35746-1)		5/28/22	09:30 Eastern	Drinking Water		
LCMRADM-TL-30 (630-35746-2)		5/28/22	09:31 Eastern	Drinking Water		
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analysis & accreditation compliance upon our subcontracted laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/test/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>						
Possible Hazard Identification				Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)		
Unconfirmed				<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months		
Deliverable Requested: I, II, III, IV, Other (specify)		Primary Deliverable Rank: 1		Special Instructions/OC Requirements:		
Empty Kit Relinquished by:		Date:	Time:	Method of Shipment		
Relinquished by:	Date/Time:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Custody Seals Intact <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Custody Seal No.: ER902	Cooler Temperature(s) °C and Other Remarks: 0.60c				

8